

Object Description	Description	Asbestos Presence	Asbestos Type	Material	Application	Condition	Initial Risk Rating	Date Surveyed	Date Reported	Quantity	Control	Control Rationale	Accessibility	Labelling
KTC Electrical Store and Offices Complex	ACM IKT03 X 20 Carport All Struct	No Asbestos Detected	No Asbestos	Fibre cement sheet	Linings	No Asbestos Detected		9/12/2010	9/12/2010	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G1 Carport Uppr SthWstWallLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Wall lining	No Asbestos Detected		2/06/2011	2/06/2011	14.700	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtSht InfillPnl	No Asbestos Detected	No Asbestos	Fibre cement sheet	Infill panel	No Asbestos Detected		2/06/2011	2/06/2011	1.000	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtSht InfillPnl	No Asbestos Detected	No Asbestos	Fibre cement sheet	Infill panel	No Asbestos Detected		2/06/2011	18/08/2014	10.000	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 Vinyl tiles FlrCov	No Asbestos Detected	No Asbestos	Vinyl tiles	Floor covering	No Asbestos Detected		2/06/2011	2/06/2011	0.300	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
ASA Non Directional Beacon	ACM IAS10 G1 PlntRm Fir ThrOut FlrCov	No Asbestos Detected	No Asbestos	Vinyl tiles	Floor covering	No Asbestos Detected		2/06/2011	18/08/2014	13.000	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtPpe Debris	Asbestos Removed	Non Friable	Fibre cement pipe	Debris	Asbestos Removed	Medium	13/05/2014	25/07/2014	0.400	N/A	Asbestos Has been removed	Accessible	Labels Removed
KTC Terminal Building	ACM IKT02 FbrCmtCst SrvsPitCasts	No Asbestos Detected	No Asbestos	Fibre cement casting	Service pit cast	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM StoreRm Nxt Disabled WC WallLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Wall lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM StoreRm Nxt Disabled WC ClngLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Ceiling lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 M-WC WallLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Wall lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 M-WC Cubical Prttn	No Asbestos Detected	No Asbestos	Fibre cement sheet	Cubical partition	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 M-WC ClngLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Ceiling lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 F-WC WallLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Wall lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 F-WC Cubical Prttn	No Asbestos Detected	No Asbestos	Fibre cement sheet	Cubical partition	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 F-WC ClngLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Ceiling lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 FbrCmtSht Debris	No Asbestos Detected	No Asbestos	Fibre cement sheet	Debris	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 Ext Sth/East/Wst Elev EavsLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Eaves lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 Disabled WC WallLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Wall lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Terminal Building	ACM IKT02 Disabled WC ClngLng	No Asbestos Detected	No Asbestos	Fibre cement sheet	Ceiling lining	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G13 StoreRm All Struct	No Asbestos Detected	No Asbestos	Fibre cement sheet	Linings	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G12 Wshop All Struct	No Asbestos Detected	No Asbestos	Fibre cement sheet	Linings	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtSht InfillPnl	No Asbestos Detected	No Asbestos	Fibre cement sheet	Infill panel	No Asbestos Detected		13/05/2014	25/07/2014	15.000	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G9 Office Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	12.500	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G7 Ktchnette Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G5 Office Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G16 Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G11 Office Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G10 WC Wndw Sealnt	No Asbestos Detected	No Asbestos	Mastic	Sealant	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 G9 Office Flr ThrOut FlrCov	No Asbestos Detected	No Asbestos	Vinyl tiles	Floor covering	No Asbestos Detected		13/05/2014	25/07/2014	22.800	N/A	Nil Asbestos Detected	Accessible	Labels Not Required
ASA Emergency Power House	ACM IAS02 G2 PlntRm All Struct	No Asbestos Detected	No Asbestos	Fibre cement sheet	Linings	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
ASA Emergency Power House	ACM IAS02 Battery back up Cab BckBrd	No Asbestos Detected	No Asbestos	Millboard	Backing board	No Asbestos Detected		13/05/2014	25/07/2014	1.000	N/A	Nil Asbestos Detected	Unknown	Labels Not Required
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtCst Service pit	Asbestos Present	Non Friable	Fibre cement casting	Service pit	Fair	Low	29/09/2016	9/12/2010	0.800	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtPpe Debris	Asbestos Present	Non Friable	Fibre cement pipe	Debris	Good	Low	29/09/2016	9/12/2010	0.300	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 FbrCmtPpe Debris	Asbestos Present	Non Friable	Fibre cement pipe	Debris	Good	Low	29/09/2016	9/12/2010	0.300	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G8 HallWy Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	7.000	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G5 Office FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	50.000	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G4 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	8.200	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G3 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	8.200	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G21 Airlock FlrCov ThrOut	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Good	Low	29/09/2016	9/12/2010	1.700	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G19 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Good	Low	29/09/2016	9/12/2010	9.400	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G18 Office Flr FlrCov ThrOut	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	8.600	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G17 StoreRm FlrCov ThrOut	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	44.000	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G16 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	8.900	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G15 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Good	Low	29/09/2016	9/12/2010	9.000	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G14 HallWy Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Good	Low	29/09/2016	9/12/2010	11.600	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G11 Office Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	9.500	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
KTC Electrical Store and Offices Complex	ACM IKT03 G10 WC Flr ThrOut FlrCov	Asbestos Present	Non Friable	Vinyl tiles	Floor covering	Fair	Low	29/09/2016	9/12/2010	9.200	Leave And Manage	Refer To Survey Report	Accessible	Labels Affixed
ASA Non Directional Beacon	ACM IAS10 FbrCmtCst Service pit	Asbestos Present	Non Friable	Fibre cement casting	Service pit	Good	Low	29/09/2016	9/12/2010	0.800	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Non Directional Beacon	ACM IAS10 FbrCmtCst Service pit	Asbestos Present	Non Friable	Fibre cement casting	Service pit	Good	Low	29/09/2016	9/12/2010	0.800	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Emergency Power House	ACM IAS02 FbrCmtCst Service pit	Asbestos Present	Non Friable	Fibre cement casting	Service pit	Fair	Low	29/09/2016	9/12/2010	0.800	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Emergency Power House	ACM Lvl G Ext Bid Area EavsLng NE Elevs	Asbestos Present	Non Friable	Fibre cement sheet	Eaves lining	Good	Low	29/09/2016	9/12/2010	16.800	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Emergency Power House	ACM IAS02 G1 PlntRm Walls ThrOut WallLng	Asbestos Present	Non Friable	Fibre cement sheet	Wall lining	Good	Low	29/09/2016	9/12/2010	50.000	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Emergency Power House	ACM IAS02 G1 PlntRm Clng ThrOut ClngLng	Asbestos Present	Non Friable	Fibre cement sheet	Ceiling lining	Good	Low	29/09/2016	9/12/2010	42.000	Leave And Manage	Refer To Survey Report	Not Accessible	Labels Affixed
ASA Emergency Power House	ACM IAS02 FbrCmtSht ClngLng	Asbestos Present	Non Friable	Fibre cement sheet	Ceiling lining	Good	Low	29/09/2016	9/12/2010	1.600	Encapsulate	Refer To Survey Report	Not Accessible	Labels Affixed

KTC Electrical Store and Offices Complex aka 'Comms Bldg' & 'Warehouse'